

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 3295-0855:102 Page 1 of 1

**CATEGORY:** Fire-Rated Door

**LISTEE:** Openings, 40 W Howard, Pontiac MI 48058  
Contact: Leon Yulkowski (313) 335-7380

**DESIGN:** Steel covered polystyrene foam. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, hourly rating and CSFM label.

**APPROVAL:** Listed as a 3-hour (A) fire-rated door when installed in a frame approved for the wall construction.

**NOTE:** Formerly 3375-0855:102



---

This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager